



**Retail Outlet Classification and Maximum Floor Stock Requirement.**

<b>Classification</b>	<b>Maximum Floor Stock Requirement</b>	<b>Definition</b>
1. Pure LPG Retail Outlets	Maximum aggregate quantity of LPG stored inside the establishment is 350 kgs for all brands and sizes.	<i>Refers to a natural or juridical person involved in the sale of LPG in cylinders directly to end consumers, having a maximum aggregate quantity of LPG stored inside the establishment is <b>350 kgs for all brands and sizes.</b></i>
2. Retail Outlets with other merchandise	Maximum aggregate quantity of LPG stored inside the establishment is 110 kgs for all brands and sizes.	<i>Refers to a natural or juridical person involved in the sale of LPG in cylinders directly to end consumers, having a maximum aggregate quantity of LPG stored inside the establishment is <b>110 kgs for all brands and sizes.</b></i>
	Maximum aggregate quantity of LPG less than 1kg stored inside the establishment is 110 kgs for all brands.	<i>Refers to a natural or juridical person involved in the sale of LPG less than 1kg directly to end consumers, having a maximum aggregate quantity of LPG stored inside the establishment is <b>110 kgs for all brands (40 crates of 12 pcs).</b></i>