

Annex 17. Visayas Annual System Peak Demand per Sub-Grid, 1995-2016 (in MW)

Year	CEBU	% AAGR	NEGROS	% AAGR	PANAY	% AAGR	LEYTE-SAMAR	% AAGR	BOHOL	% AAGR	TOTAL VISAYAS	% AAGR
1995	248		113		88		116		21		586	
1996	272	9.73	127	12.61	95	7.03	116	0.30	22	5.69	632	7.87
1997	291	7.10	141	10.66	114	20.76	152	30.41	24	7.17	722	14.15
1998	297	2.06	136	(3.70)	114	(0.47)	127	(15.96)	28	15.90	702	(2.79)
1999	333	12.16	152	12.03	81	(28.65)	126	(1.10)	30	8.66	722	2.97
2000	353	6.04	156	2.45	84	3.45	122	(3.25)	32	4.98	746	3.33
2001	377	6.65	151	(2.78)	146	73.92	156	28.09	31	(3.39)	861	15.33
2002	349	(7.40)	178	17.45	113	(22.39)	162	3.91	40	30.88	842	(2.16)
2003	422	20.97	179	0.94	105	(7.61)	175	7.93	41	3.28	923	9.54
2004	417	(1.14)	199	10.86	122	16.68	167	(4.52)	49	18.73	955	3.46
2005	438	4.94	195	(2.03)	120	(1.91)	168	0.65	46	(6.33)	967	1.28
2006	458	4.68	199	1.87	123	2.64	171	1.43	46	0.44	997	3.09
2007	477	4.12	209	5.11	182	48.20	186	8.76	49	5.42	1,102	10.61
2008	522	9.39	218	4.30	203	11.49	182	(2.21)	52	6.17	1,176	6.68
2009	559	7.07	215	(1.13)	223	9.91	188	3.49	56	7.77	1,241	5.52
2010	674	20.56	263	22.29	243	8.68	204	8.33	48	(14.21)	1,431	15.31
2011	704	4.44	245	(6.75)	260	7.25	209	2.81	62	30.83	1,481	3.50
2012	747	6.20	256	4.45	262	0.48	221	5.65	65	3.42	1,551	4.71
2013	780	4.41	253	(1.40)	272	3.82	199	(10.08)	63	(2.25)	1,567	1.01
2014	862	10.45	266	5.38	264	(2.72)	181	(8.74)	62	(2.23)	1,636	4.40
2015	850	(1.34)	309	15.92	309	16.84	230	26.54	70	14.18	1,768	8.09
2016	936	10.09	316	2.17	331	7.12	241	4.96	69	(1.69)	1,893	7.05