

		LUZON					
FUEL TYPE	Capac	ity (MW)	Percent	Share (%)			
	Installed	Dependable	Installed	Dependable			
Coal	9,392	8,589	44.2	45.8			
Oil Based	2,054	1,648	9.7	8.8			
Diesel	937	803	4.4	4.3			
Oil Thermal	350	305	1.6	1.6			
Gas Turbine	767	540	3.6	2.9			
Natural Gas	3,731	3,281	17.6	17.5			
Renewable Energy	6,055	5,252	28.5	28.0			
Biomass	175	145	0.8	0.8			
Biomass	167	142	0.8	0.8			
Waste to Energy (WTE)	8	3	0.0	0.0			
Geothermal	865	714	4.1	3.8			
Solar	2,121	1,674	10.0	8.9			
Behind-the-Meter (BTM)	46	44	0.2	0.2			
Ground-Mounted	2,075	1,631	9.8	8.7			
Hydro	2,558	2,382	12.0	12.7			
Impounding Hydro	1,418	1,316	6.7	7.0			
Pumped Hydro	736	720	3.5	3.8			
Run-of-River (ROR)	404	346	1.9	1.8			
Wind	337	337	1.6	1.8			
Onshore Wind	337	337	1.6	1.8			
Off-shore Wind (OSW)	0	0	0.0	0.0			
TOTAL	21,232	18,770	100.0	100.0			
Energy Storage System (ESS)	363	341					
Battery ESS	363	341					
Hybrid ESS	0	0					


		LUZ	ON			
TYPE OF CONNECTION	Capacity (MW)		Percent Share (%)			
	Installed	Dependable	Installed	Dependable		
Grid Connected	20,225	18,068	95.3	96.3		
Embedded	1,007 703		4.7	3.7		
TOTAL	21,232	18,770	100.0	100.0		
Energy Storage System (ESS)	363	341				
Battery ESS	363	341				
Hybrid ESS	0	0				






	VISAYAS					
FUEL TYPE	Capac	ity (MW)	Percent	Share (%)		
	Installed	Dependable	Installed	Dependable		
Coal	1,346	1,233	34.9	37.4		
Oil Based	561	450	14.5	13.6		
Diesel	550	439	14.3	13.3		
Oil Thermal	11	11	0.3	0.3		
Gas Turbine	0	0	0.0	0.0		
Natural Gas	1	0	0.0	0.0		
Renewable Energy	1,951	1,613	50.6	48.9		
Biomass	326	195	8.4	5.9		
Biomass	326	195	8.4	5.9		
Waste to Energy (WTE)	0	0	0.0	0.0		
Geothermal	975	888	25.3	26.9		
Solar	505	411	13.1	12.5		
Behind-the-Meter (BTM)	0	0	0.0	0.0		
Ground-Mounted	505	411	13.1	12.5		
Hydro	55	44	1.4	1.3		
Impounding Hydro	0	0	0.0	0.0		
Pumped Hydro	0	0	0.0	0.0		
Run-of-River (ROR)	55	44	1.4	1.3		
Wind	90	75	2.3	2.3		
Onshore Wind	90	75	2.3	2.3		
Off-shore Wind (OSW)	0	0	0.0	0.0		
TOTAL	3,860	3,296	100.0	100.0		
Energy Storage System (ESS)	129	122				
Battery ESS	129	122				
Hybrid ESS	0	0				

		VISA	YAS			
TYPE OF CONNECTION	Capacity (MW)		Percent Share (%)			
	Installed	Dependable	Installed	Dependable		
Grid Connected	3,726	3,178	96.5	96.4		
Embedded	134	119	3.5	3.6		
TOTAL	3,860	3,296	100.0	100.0		
Energy Storage System (ESS)	129	122				
Battery ESS	129	122				
Hybrid ESS	0	0				






CAPACITY MIX, MW				
Installed and Dependable Capacity				


		MINDANAO					
FUEL TYPE	Capac	ity (MW)	Percent	Share (%)			
	Installed	Dependable	Installed	Dependable			
Coal	2,268	2,041	49.1	50.8			
Oil Based	833	708	18.1	17.6			
Diesel	833	708	18.1	17.6			
Oil Thermal	0	0	0.0	0.0			
Gas Turbine	0	0	0.0	0.0			
Natural Gas	0	0	0.0	0.0			
Renewable Energy	1,513	1,271	32.8	31.6			
Biomass	95	37	2.1	0.9			
Biomass	95	37	2.1	0.9			
Waste to Energy (WTE)	0	0	0.0	0.0			
Geothermal	112	106	2.4	2.6			
Solar	84	68	1.8	1.7			
Behind-the-Meter (BTM)	0	0	0.0	0.0			
Ground-Mounted	84	68	1.8	1.7			
Hydro	1,223	1,059	26.5	26.3			
Impounding Hydro	747	619	16.2	15.4			
Pumped Hydro	0	0	0.0	0.0			
Run-of-River (ROR)	476	440	10.3	10.9			
Wind	0	0	0.0	0.0			
Onshore Wind	0	0	0.0	0.0			
Off-shore Wind (OSW)	0	0	0.0	0.0			
TOTAL	4,615	4,020	100.0	100.0			
Energy Storage System (ESS)	142	136					
Battery ESS	93	87					
Hybrid ESS	49	49					


		MIND	NAO			
TYPE OF CONNECTION	Capacity (MW)		Percent Share (%)			
	Installed	Dependable	Installed	Dependable		
Grid Connected	3,763	3,291	81.5	81.9		
Embedded	852	729	18.5	18.1		
TOTAL	4,615	4,020	100.0	100.0		
Energy Storage System (ESS)	142	136				
Battery ESS	93	87				
Hybrid ESS	49	49				



		PHILIPPINES					
FUEL TYPE	Capac	ity (MW)	Percent	Share (%)			
	Installed	Dependable	Installed	Dependable			
Coal	13,006	11,863	43.8	45.5			
Oil Based	3,448	2,806	11.6	10.8			
Diesel	2,320	1,951	7.8	7.5			
Oil Thermal	361	316	1.2	1.2			
Gas Turbine	767	540	2.6	2.1			
Natural Gas	3,732	3,281	12.6	12.6			
Renewable Energy	9,520	8,136	32.0	31.2			
Biomass	595	378	2.0	1.4			
Biomass	587	374	2.0	1.4			
Waste to Energy (WTE)	8	3	0.0	0.0			
Geothermal	1,952	1,708	6.6	6.5			
Solar	2,710	2,154	9.1	8.3			
Behind-the-Meter (BTM)	46	44	0.2	0.2			
Ground-Mounted	2,664	2,110	9.0	8.1			
Hydro	3,836	3,485	12.9	13.4			
Impounding Hydro	2,164	1,935	7.3	7.4			
Pumped Hydro	736	720	2.5	2.8			
Run-of-River (ROR)	936	831	3.1	3.2			
Wind	427	412	1.4	1.6			
Onshore Wind	427	412	1.4	1.6			
Off-shore Wind (OSW)	0	0	0.0	0.0			
TOTAL	29,706	26,087	100.0	100.0			
Energy Storage System (ESS)	634	599					
Battery ESS	585	550					
Hybrid (Diesel-Battery System)	49	49					

		PHILIP	PINES			
TYPE OF CONNECTION	Capacity (MW)		Percent Share (%)			
	Installed	Dependable	Installed	Dependable		
Grid Connected	27,713	24,537	93.3	94.1		
Embedded	1,993	1,551	6.7	5.9		
TOTAL	29,706	26,087	100.0	100.0		
Energy Storage System (ESS)	634	599				
Battery ESS	585	550				
Hybrid ESS	49	49				





11510

Note:

Excluding off-grid generators

Released as of 31 December 2024

Installed Capacity - nameplate capacity; full-load continuous gross capacity of a unit under specified conditions, as calculated from the electric generator nameplate based on the rated power factor.

Dependable Capacity - maximum capacity when modified for ambient limitations for a specified period of time, such as a month or a season.

Installed and Dependable Capacity values may be updated as necessary.

For Solar Power Plants: Installed Capacity are MWP or MWDC values while Dependable Capacity are MWAC values

GRID	Capaci	city (MW) Perce		Share (%)	Number of
	Installed	Dependable	Installed	Dependable	<b>Power Plants</b>
LUZON	21,232	18,770	71.5	72.0	156
VISAYAS	3,860	3,296	13.0	12.6	65
MINDANAO	4,615	4,020	15.5	15.4	77
TOTAL	29,706	26,087	100.0	100.0	298