

TYPHOON PABLO POWER RESTORATION UPDATE 18

AS OF DECEMBER 20, 2012 12:00 PM Updates

(Sources: National Electrification Administration/National Grid Corporation of the Philippines, DOE Electric Power Industry Management Bureau)

PROVINCE/ DISTRIBUTION UTILITY (# OF MUNICIPALITY)	AFFECTED MUNICIPALITY (# OF AREA AFFECTED)	RESTORED MUNICIPALITY (# OF MUNICIPALITIES RESTORED)	TARGET DATE OF FULL RESTORATION MUNICIPALITIES	# OF BRGYS	# OF UNERGIZED BARANGAYS	# OF ENERGIZED BARANGAYS	% of POWER RESTORED BARANGAY	TARGET DATE OF FULL RESTORATION BARANGAY
Agusan del Sur ASELCO (14)	(0)	Bayugan City Esperanza La Paz Prosperidad Rosario San Francisco San Luis Sibagat Talacogon Bunawan Santa Josefa Trento Veruela Loreto (14)	December 17 (Restored)	255	39	216	85%	December 23
Surigao del Sur SURSECO 1 (5)	(0)	Barobo Hinatuan Tagbina Lingig (5)	December 12 (Restored)	113	17	96	85%	December 22
Surigao del Sur SURSECO 2 (14)	(0)	Bayabas Cagwait Cantilan Carmen Carrascal Cortes	December 4 (Restored)	197	0	197	100%	December 9 (Restored)

		Lanuza Lianga Madrid Marihatag San Agustin San Miguel Tago Tandag City (14)						
Misamis Oriental MORESCO 2 (13)	(0)	Balingasag Balingoan Binuangan Claveria Gingoog City Jasaan Kinoguitan Lagonglong Magsaysay (Linugos) Medina Salay Subongcogon Talisayan (9)	December 8 (Restored)	278	12	266	95%	December 20
Bukidnon BUSECO (11)	(0)	Baungon Cabanglasan Impasugong Lantapan Libona Malaybalay Malitbog Manolo Fortich Sumilao Talakag Valencia (11)	December 10 (Restored)	172	0	172	100%	December 19 (Restored)

Dinagat DIELCO (7)	(0)	Basilisa (Rizal) Cagdianao Dinagat Loreto San Jose Tubajon (7)	December 6 (Restored)	100	0	100	100%	December 6 (Restored)
Siargao SIARELCO(9)	(0)	Burgos Dapa Del Carmen General Luna Pilar San Benito San Isidro Santa Monica Socorro (9)	December 5 (Restored)	133	0	133	100%	December 5 (Restored)
Camiguin CAMELCO (5)	(0)	Catarman Guinsiliban Mahinog Mambajao Sagay (5)	December 6 (Restored)	58	0	58	100%	December 12 (Restored)
Lanao del Norte LANECO (22)	(0)	(77)	106	58%	0	402	100%	December 13 (Restored)
Davao Oriental DORECO (11)	Caraga (1)	Banaybanay Governor Generoso Lupon Mati City San Isidro Tarragona Manay (10)	December 24	183	71	112	61%	December 24*

		Banganga Boston Cateel	December 16 (town center energized)					December 31*
Davao del Norte Compostella Valley DANECO (20)	(0)	Mabini Maco Mawab Nabunturan Pantukan Tagum City New Corella Samal Montevista Talaingod Kapalong Kaputian Babak Asuncion (Saug) Compostela Monkayo San Isidro New Bataan Laak (San Vicente)	December 20	374	104	156	42%	December 23
		Maragusan (San Mariano) (20)	December 19 (town center energize)					December 31*
Davao Light and Power Corporation DLPC (5)	(0)	Davao City (5)						
Iligan City Iligan Light Power Inc. ILPI		Iligan City	Within the week					

Cagayan Electric Power and Light Company CEPALCO		Cagayan de Oro City Tagoloan Villanueva Jasaan (PHIVIDEC Estate)	Within the week				
Cotabato Light COLIGHT							

NGCP Restoration Accomplishment Report as of December 19, 2012 5:00 PM

LINE	DESCRIPTION OF DAMAGE (No. of Structures)				CUSTOMERS AFFECTED	TARGET DATE OF RESTORATION	STATUS
	TOPPLED	ERECTED	LEANING	CORRECTED			
DISTRICT 4: North Eastern Mindanao							
Bislig-Cateel 69 kV Line segment	192	174	8	8	SURSECO I, DORECO	23-Dec-12	On-schedule
Cateel-Baganga 69 kV Line segment	256	10	20	1			On-schedule
Bislig-Trento 69 kV Line	19	19	12	12	ASELCO	Restored: 12/11 at 1445H	
Bislig-San Fernando 69 kV Line ¹	10		1		SURSECO I	23-Dec-12	On-schedule
DISTRICT 5: South Eastern Mindanao							
Bislig-Nabunturan 138 kV Line	1	1 Emergency Restoration System	-	-	none	Restored: 12/11 at 1537H	
Nabunturan-Monkayo 69 kV Line	40	40			DANECO	Restored: 12/18 at 0603H	
Nabunturan-Auncion 69 kV Line	32	32			DANECO	Restored: 12/18 at 0604H	

1. Power on affected customer is supplied through San Francisco SS

MINDANAO OVERVIEW

TYPHOON PABLO POWER RESTORATION UPDATES

(as of December 20, 2012 12:00 p.m.)

